



Structural Permit Application Covered or Enclosed Multilevel Exhibit Booth

Covered/Enclosed exhibit areas shall meet the Broward County Fire Department regulations. Please complete this portion and return at least 60 days prior to your event. Please submit two (2) copies of the plans to:

Broward County Convention Center
Event Services Department
1950 Eisenhower Blvd
Ft. Lauderdale, FL 33316

Phone: 954 765-5900
Fax: 954 763-9551
Website: ftlauderdalecc.com

Show/Event Name _____ Booth #: _____

Exhibitor/Company Name _____

Exhibitor Address _____

City _____ State _____ Zip _____

Phone _____ Fax _____

On-site Contact _____

An engineered drawing bearing the stamp of a certified structural engineer needs to be included with application.

THIS PORTION TO BE COMPLETED BY THE FORT LAUDERDALE FIRE DEPARTMENT

Comments _____

Approved by _____ **Date** _____
Fort Lauderdale Fire Marshall



COVERED OR MULTILEVEL EXHIBITS GUIDELINES

COVERED EXHIBITS LESS THAN 300 SQ FT

1. Exhibit Structures and decorative material within the exhibit should be made of non-combustible or limited combustible (flame-retardant) materials. Materials need to comply with NFPA 701 & 703. Certificates of flame retardant need to be available on-site if requested by the Ft. Lauderdale Fire Rescue Department & Fire Prevention Bureau.
2. Exhibit Structures should be furnished with a battery-powered smoke detector on the interior of the structure.
3. Each enclosed area shall include Fire extinguishers with a minimum class of 2A10BC, dry chemical fire extinguisher.

COVERED EXHIBITS LARGER THAN 300 SQ FT OR MULTI-LEVEL EXHIBITS

1. Two (2) copies of the Exhibit Structure plans need to be submitted along with the Structure permit and Application to the Broward County Convention Center for review by the Fort Lauderdale Fire Rescue Department & Fire Prevention.
2. Plans must be scaled, signed and dated by a certified structural engineer.
3. Exhibit Structures and decorative material within the exhibit should be made of non-combustible or limited combustible (flame-retardant) materials. Materials need to comply with NFPA 701 & 703. Certificates of flame retardant need to be available on-site if requested by the Ft. Lauderdale Fire Rescue Department & Fire Prevention Bureau.
4. Exhibit Structures should be furnished with a battery-powered smoke detector on the interior of the structure.
5. Each enclosed area shall include Fire extinguishers with a minimum class of 2A10BC, dry chemical fire extinguisher.
6. All covered booths larger than 300 sq ft shall require a sprinkler system as per NFPA 101.
7. Upper level may not have a "COVER" of any kind (e.g., roof, ceiling, tenting, lattice, fabric.)
8. Guardrails should be at least 42" inches (1.07m) in height and have intermediate rails throughout with a Four inch (15.24cm) sphere cannot pass.
9. Stairs should be:
 - a). Minimum of three feet thirty-six (36") in width.
 - b). Equipped with handrails.
 - c). Risers maximum height of seven inches (7") & minimum height of four inches (4").
 - d). Treads shall be minimum of eleven inches (11").
 - e). Spiral stairs are not permitted.
10. Upper level floor systems should support a live load of hundred lbs (100) per square foot.
11. Two (2) exits are required for every 300 square feet of occupied space.
12. All booth construction shall meet local, state, & federal mandated codes and sections.